



NOTES:

1. SERVICE LINE STUB MUST EXTEND TO THE PROPERTY LINE. A DISCONNECT CLEANOUT SHALL BE INSTALLED ON THE PUBLIC SIDE AT THE PROPERTY LINE.
2. INTEGRAL WYE FITTINGS ON THE SEWER MAIN ARE TO BE USED FOR THE CONNECTION OF THE SERVICE LINE TO THE SEWER MAIN. FOR IN-SERVICE MAINS, USE DETAIL SM442.
3. THE DEPTH OF THE SEWER LINE AT THE PROPERTY LINE SHALL NOT BE LESS THAN 3.75 FEET, NOR MORE THAN 5 FT AS MEASURED FROM THE TOP OF THE PIPE TO THE SURROUNDING GRADE UNLESS THE DISTANCE TO THE BUILDING REQUIRES GREATER DEPTH.
4. BEDDING FROM 4" BELOW BOTTOM OF THE SERVICE LINE TO 12" OVER THE TOP OF PIPE SHALL BE PER DETAIL SM200.
5. #14 BARE COPPER TRACER WIRE ACCESSIBLE AT R/W AND AT PROPERTY OWNER CLEANOUT.



SEWER BUILDING CONNECTION

REVISED
JUL-15-2024

DETAIL NO.
AJS440