


NOTES:
 INTERCEPTOR SHALL BE WATERTIGHT.
 INSIDE AND OUTSIDE OF INTERCEPTOR SHALL BE COATED WITH ASPHALT EMULSION.
 CONCRETE SHALL BE CLASS A (MAG SEC. 725, MINIMUM OF 3000 PSI COMPRESSIVE STRENGTH AT 28 DAYS).

 APACHE JUNCTION SEWER DISTRICT RECLAIMING WATER FOR THE FUTURE	
GREASE INTERCEPTOR DETAIL	
REVISED JUL-15-2024	DETAIL NO. AJS430